



Kerala State Electricity Board Limited

(Incorporated under the Companies Act, 1956)

Registered Office: Vidyuthi Bhavanam, Pattom,
Thiruvananthapuram 695 004

CIN:U40100KL2011SGC027424 Website: www.kseb.in

Phone: +91 471 2514685, 2514331, Fax: 0471 2447228

E-mail ID: mdksebk@ksebnct.com, ddksebk@ksebk.in

ABSTRACT

Providing Temporary LT connection to M/s. Indus Towers from existing HT consumer- M/s. HPCL- Sanctioned- Orders issued.

CORPORATE OFFICE (SBU-D)

B.O(FTD)No.294 /2019(D(D&IT)/D2/SOP/2018-19/ Dated, Thiruvananthapuram 02.04.2019

- Read:
1. Letter no. CE(DC)/AEE2/HT/Indus/2018-19/4945 dated 23.03.2019 of the Chief Engineer, (Distribution Central) Ernakulam
 2. B.O. (FTD) No. 887 /2015 (D(D&S)/D3/AEE/BSNL/4583/2017) TVPM dated 10.04.2015
 3. Note no. KSEB/S Code/Ahalya/R2/2016/2975/20/7/2016 of the Chief Engineer (Commercial and Tariff)
 4. Note no. D(D&IT)/D-2/SOP/00282018-19 dated 22.03.2019 of the Director (Distribution and IT)(Agenda no 77/3/19)

ORDER

M/s. Indus Tower has requested for LT connection with a connected load of 8.38kW for their newly erected mobile tower in the premises of M/s. HPCL. M/s. HPCL is a HT consumer under Electrical Section, Vaduthala with a contract demand of 100kVA. But the LT connection can be given only by crossing the railway line. It is reported that the Assistant Engineer, Electrical Section, Vaduthala has requested for sanction from the Railway Authorities for crossing their line. But obtaining sanction will take time. Hence, M/s Indus Tower has requested to provide a temporary LT connection for a period of one month to their premise from the HT connection of M/s. HPCL, as the mobile tower has to be operated urgently. It is also reported that they are ready to pay the charges applicable for the temporary LT connection. M/s. HPCL has issued a certificate dated 12.02.2019 informing that they have no objection for temporarily extending the connection from their premise for providing LT supply to the premise of M/s. Indus Tower. Presently, M/s. HPCL is charged under HT IV(Commercial) tariff & the tariff to be assigned to Mobile Tower is LT VI(F) General. As per Deputy Chief Engineer, Electrical Circle, Ernakulam the request of M/s. Indus Tower to provide temporary LT connection from the existing HT consumer is now indicated for a period of one month, but could be extendable till sanction for laying cable is obtained from the Railway Authorities. It is recommended that by providing temporary LT supply from the HT consumer premises, there will not be any adverse financial implication to KSEBL and the energy consumed by the LT consumer can be

deducted from the total consumption of the HT connection. However, the demand charges cannot be segregated. It is further recommended that the HT consumer has given unconditional consent and as the temporary LT connection is only for a limited period, the request can be considered favourably.

The matter was placed before the Full Time Directors vide note read 4 above.

Having examined the matter in detail, the Full Time Directors in the meeting held on 28.03.2019 resolved to accord sanction to the Deputy Chief Engineer, Electrical Circle, Ernakulam to provide temporary LT service connection to the Indus Towers inside the premises of M/s. HPCL as LT consumer from distribution point in the secondary side of the transformer of HT consumer, M/s. HPCL through a sub meter on a provisional basis subject to the following conditions:

- The Electrical Inspectorate shall approve the scheme.
- The prospective consumer shall bear the cost and submit necessary documents as similar to new connection for availing supply from the distributing point of the HT consumer as per the prevailing norms. The prospective LT consumer, HT consumer and KSEBL shall jointly decide the position of the meter.
- The consumption recorded in the Sub Meter of the Indus Mobile Tower shall be deducted from the consumption recorded by the HT consumer. The HT consumer shall pay the additional demand charges, if there is an increase in MD due to the consumption by the LT consumer. Any charges applicable on account of low power factor, harmonic dumping etc (as approved by the commission) shall be paid by the HT consumer. The HT consumer shall execute a supplementary agreement to this effect.
- The Meter reading of the Sub meter of the Indus Mobile Tower shall be taken every month with the HT reading of M/s. HPCL.
- A special condition shall be incorporated in the service connection agreement of the LT consumer, M/s Indus Towers that in the event of surrendering of the HT service connection or if any other unforeseen event arises by which KSEBL is not in a position to provide supply to the mobile tower in the proposed arrangement, the LT consumer shall avail supply through alternate arrangements. The KSEBL shall be at liberty to terminate the LT service connection agreement and disconnect /dismantle

the service connection if LT consumer fail to meet the cost for availing supply through alternate arrangement.

- The LT consumer shall also indemnify KSEBL from the liabilities of Standards of performance, if KSEBL is unable to provide supply due to failure of plants /equipment, maintenance of which is the responsibility of the HT consumer or in the event of KSEBL disconnecting/ dismantling the service to the HT consumer due to failure on their part to oblige the service connection agreement, including but not limited to non remittance of amounts due to KSEBL.
- M/s Indus Tower shall not claim this method of providing LT service connection as a precedent in other locations/ premises.
- M/s HPCL shall submit an undertaking that a single point supply shall be availed by them as and when the same is demanded by KSEBL.

Orders are issued accordingly.

By Order of the Full Time Directors

Sd/-

Lekha G.

Company Secretary In Charge


To

1. The Chief Engineer, Distribution (Central)
2. The Deputy Chief Engineer, Electrical Circle, Ernakulam
3. The Special Officer Revenue

Copy to:

1. The Chief Engineer (IT & CR)/Financial Advisor/ Chief Internal Auditor
2. The TA to Chairman & Managing Director
3. The TA to Director (Distribution & IT/ Transmission & System Operation/ Corporate Planning, Generation-Electrical, Supply Chain Management & Safety/ Generation-Civil & HRM)
4. The RCAO/ECA, Vydyuthi Bhavanam, Pattom/RAO, Electrical Circle, Ernakulam
5. The Legal Liaison Officer, Power House, Kochi
6. The PA to Director (Finance) /Senior C.A. to Secretary (Administration)/Company Secretary
7. Fair Copy Section / Library / Stock File.

Forwarded / By Order


Assistant Executive Engineer