



KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under Companies Act, 1956)

CIN: U40100KL2011SGC027424

Registered Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram - 695004 Website: www.kseb.in

Phone:(O) +91 471 2514283 E-mail: dgekseb@kseb.in

Abstract

Idamalayar HEP - Total shutdown for replacement of LT Panel –Sanctioned–Orders issued.

Corporate Office (SBU-G/E)

B.O.(FTD) No.657 /2019 (DGE/G3/Kakkayam/2019-20) Thiruvananthapuram dated: 02-09-2019

- Ref:-
1. Letter No.CEG/AE-VII/IDMR/GNL/2019-20/ 826 dtd: 21.08.2019 of the Chief Engineer (Generation &PED).
 2. Note No.DGE/G3/Shutdown/Idamalayar/ 2019-20 dated:24-08-2019 of the Director (CP,GE,SCM& Safety) (Agenda Item No.73/08/19)

ORDER

The Chief Engineer (Generation &PED) as per letter read (1) above requested sanction for total shutdown of Idamalayar HEP, from 26.08.2019 to 04.09.2019 , for carrying out the erection and commissioning of new LT Panel after dismantling the old panel at Idamalayar Power House.

It is reported that the existing LT Panel at Idamalayar Power House is single bus type, having difficulty in maintenance. The entire AC supply has to be switched off during maintenance of LT Bus bar and there is no bus sectionalizer in the panel. As per the safety and technical audit report, the old LT panel has to be replaced urgently. Accordingly, the work for erection and commissioning of new LT Panel after dismantling of existing panel was awarded to M/s SVG Control Systems Pvt. Ltd., Bangalore. As the new LT panel is ready for installation at Idamalayar Power Station, Chief Engineer (Generation & PED) has requested sanction for the total shutdown of the plant from 26.08.2019 to 04.09.2019 .

Having considered the recommendation in the Note read as 2nd paper above, the Full Time Directors meeting held on 30-08-2019, resolved to accord in-principle sanction for the total shutdown of Unit#1 and Unit#2 at Idamalayar HEP from 26.08.2019 to 04.09.2019 for the replacement of LT panel.

Further resolved that the action plan fixing the exact date of shutdown shall be prepared by the Chief Engineer(Generation) in consultation with the Chief Engineer (Transmission & System Operation)

Orders are issued accordingly.

By Order of the Full Time Directors,

Sd/-

(LEKHA.G)

Company Secretary

(In -charge.)

- To: 1.The Chief Engineer (Generation& PED),Moolamattom.
2.The Chief Engineer (Transmission & System Operation),Kalamassery

Copy to:The Deputy Chief Engineer, Generation Circle, Kothamangalam
The Financial Advisor/The Chief Internal Auditor,
The TA to CMD/D(CP,GE,SCM&S)/ D(T&SO)/ D(D&IT)/D(GC&HRM)
The Fair copy Superintendent/Library/Stock File

Forwarded / By Order

Asst. Executive Engineer

DESPATCHED

No. 167
Date 03.09.19