



KERALA STATE ELECTRICITY BOARD Ltd
 (Incorporated under the Companies Act, 1956)
 Registered Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004
 CIN: U40100KL2011SGC027424 Web: www.kseb.in
 Phone : 0471-2446853
 Email : cescm@kseb.in

ABSTRACT

Supply of 11 kV/433 V, 315 kVA & 500kVA BEE Energy Efficiency Level 1 (1 star) Distribution Transformers with ISI marking - Exemption in furnishing the Type Test report - Sanctioned - Orders issued.

Corporate Office (Procurement & Supply Chain Management)

B.O. (FTD) No.205 / 2024 (XD/AE3/SCM.38/2023-24)
 Thiruvananthapuram.

Dated:06-05-2024

- Read :
1. P.O. No. SCM.24/2023-24 dated 04.07.2023.
 2. P.O. No. SCM.38/2023-24 dated 12.09.2023.
 3. Request letter received from M/s KEL, Kochi dated 19.01.2024.
 4. Note No.SCM/XD/AE3/SCM.38/2023-24 dated 23.02.2024 submitted to the Director (D,S & SCM).
 5. Note No. XD/AE3/SCM.38/2023-24 dated 05.03.2024 of the Chief Engineer (P&SCM) to the Full Time Directors (Agenda No.12-05/2024).

ORDER

Purchase Orders for the supply of 11 nos of 11kV/433V, 500kVA DTRs and 5 nos of 11kV/433V, 315kVA DTRs were issued to M/s KEL, Kochi as per Purchase Orders read as 1st & 2nd above. As per the delivery schedule in the P.O., the supply of 11 nos of 500kVA transformers have to be completed by 04.01.2024 and 5 nos of 315kVA transformers have to be completed by 12.12.2023. But, till date no inspection call letter was received from the firm.

Now, the firm M/s KEL as per their letter read as 3rd above, stated that they have manufactured 1 no each of 500 kVA and 315 kVA DTRs for testing and requested to exempt them from furnishing the type test reports for both the transformers, as all the NABL accredited labs are fully booked and they didn't get any specific date for the testing yet.

The Chief Engineer (P&SCM) as per note read as 4th above has reported that in the case of 500kVA transformers, M/s KEL, is the previous supplier of KSEBL for the FY 2022-23 and they had furnished the valid type test report (type test conducted on January 2018) for the year. Also, the firm had completed the supply of transformers in time. As the validity of the type tests, required as per the tender condition is 5 years, the validity exhausted on January 2023, and this type test is not valid during the period of tendering for the FY 2023-24. In this case, the L2 bidder is not willing to match with the L1 rate.

Also, in the case of 315kVA transformers, the firm had not furnished the type test report yet and is not a previous supplier of the item to KSEBL. The L2 bidder in the tender, M/s Kanyaka Parameswari Engineering Ltd, Hyderabad, (Our previous supplier) is willing to match with the L1 rate and they had the valid type test report also. The L2 bidder agreed to supply the transformers at their quoted losses, (the total loss offered by L1 & L2 bidders at 50% load is 1025W & 1025 W and at 100% load, 3100W & 2802 W respectively).

Accordingly, note read as 4th above was submitted to the Director (D,S & SCM) to confirm the requirement of the transformers and to decide whether to exempt M/s KEL from furnishing the type test report for both 500kVA & 315 kVA transformers and allow them to supply the transformers as per the respective purchase orders or to exempt M/s KEL from furnishing the type test for 500kVA transformers only and allow them to supply the 500 kVA transformers and alternate purchase may be arranged from the L2 bidder for 315 kVA DTRs, who is willing to match with the L1 rate or ask M/s KEL for furnishing the type test report immediately for both the ratings and then allow to supply the transformers.

As per the direction from the Director (D,S & SCM), note read as 5th above was placed before the Full Time Directors.

Having considered the matter in detail, the Full Time Directors, resolved to exempt M/s KEL from furnishing the type test for 500kVA transformers only, as there is no change in design and allow them to supply the 500 kVA transformers.

Resolved further to cancel the purchase order for 315 kVA transformer placed with M/s KEL and to place purchase order for 315 kVA transformer with the L2 bidder who is willing to match with the L1 rate after obtaining legal opinion in this regard.

Orders are issued accordingly.

By Order of the Full Time Directors

Signed by

Lekha G

Date: 06-05-2024 18:12:28

LEKHA G

COMPANY SECRETARY

To:

The Chief Engineer (P&SCM)

Copy to:

The Company Secretary / Chief Engineer (IT,CR&CAPS) / Financial Advisor / LA&DEO / Chief Internal Auditor / Chief Vigilance Officer

The TA to the Chairman & Managing Director / Director (Generation-Civil) / Director (Distribution, Safety, SCM & IT) / Director (Transmission, SO & Planning) / Director (Generation - Electrical, REES, SOURA, Sports & Welfare)

The PA to the Director (Finance & HRM)

The Sr.CA to the Secretary (Administration)

The RCAO/ RAO

Stock File.

Forwarded / By Order



Assistant Engineer