



**KERALA STATE ELECTRICITY BOARD Ltd**  
 (Incorporated under the Companies Act, 1956)  
 Registered Office: Vydyuthi Bhavanam, Pattom, Thiruvananthapuram – 695004  
 CIN: U40100KL2011SGC027424 Web: www.kseb.in  
 Phone :+914712514685, 2514331 Email: ddkseb@kseb.in

-----  
**ABSTRACT**

Fairy Moss Private Limited, Thumbachal, Thiruvambady, Kozhikode- Request for remitting the estimated amount in instalments - Sanctioned - Orders issued.

-----

**CORPORATE (SBU - D)**

B.O. (FTD) No. 166/2024 ( AE3/2023/5160) Thiruvananthapuram.

Dated:22-04-2024

-----

- Read :
1. Letter No. 1014/Ord/M(Ele)/2023 of the Hon'ble Minister for Electricity dated. 06.06.2023
  2. Letter No. 1627/Ord/M(Ele)/2023 of the Hon'ble Minister for Electricity dated. 12.9.2023
  3. Letter No. ECK/T S1/Complaint/2023-24/2436 of the Deputy Chief Engineer Electrical Circle Kozhikode dated 07.10.2023
  4. Note No. DIRDIT-AE3/2023/5160 (4) dated 20.01.2024 of the Director (Distribution, Safety & SCM) to the Full Time Directors (Agenda No.25 -04/2024).

**ORDER**

Sri Hijas Koyakkutty N C submitted a petition through Electricity Minister, read as 1<sup>st</sup> above regarding the Electricity connection to their drinking water packaging company. When the petitioner approached KSEBL, he was informed that a 11 kV line has to be drawn and another transformer has to be installed for getting the connection. The petitioner says that he is financially unable to pay for the extension of the utilities.

The petitioner submitted another letter to the Hon'ble Electricity Minister, read as 2<sup>nd</sup> above regarding the same matter and it is commented in the letter to allow the petitioner to remit 25% of the amount as first installment and to remit the balance in 6 installments as a special case.

The Deputy Chief Engineer, Electrical Circle Kozhikode, in the letter read as 3<sup>rd</sup> above reported that the establishment named Fairy Moss Private Ltd., Thumbachal, is situated at a distance 850 m from 100 kVA Thumbachal transformer and 100 kVA Vazhikkadav transformers. It was requested that a demand of 60 kW is provided from these transformers. It is not possible to get the supply with the required voltage as per regulation, if supply is given using LT lines from the above transformers. Therefore, it is recommended to tap 11 kV line from the existing OH line for a distance of 810m and erect a new transformer. Additionally, the road from Thumbachal and Vazhikkadav transformers to Fairy Moss are narrow and with thick vegetation along side, the use of ABC is preferred for constructing 11kV line. An amount of Rs. 22,10,514/- is estimated for these works.

The matter is placed before the Full Time Directors as per note read as 4<sup>th</sup> above for a decision.

Having considered the matter in detail, the Full Time Directors

1. Resolved to accord sanction to permit the petitioner to remit 25% of the amount as first installment and to remit the balance in 6 installments, at an interest rate of 18% for the balance

amount, as a special case.

2. Further resolved that, a post dated cheque for the installments shall be submitted by the party and if the remittance is not made on the due dates, the cheque shall be presented.

Orders are issued accordingly.

By Order of the Full Time Directors

Sd/-

LEKHA G  
COMPANY SECRETARY


To:

The Chief Engineer, Distribution North  
The Deputy Chief Engineer Electrical Circle Kozhikode

Copy to:

The Company Secretary / Chief Engineer (IT,CR&CAPS) / Financial Advisor / LA&DEO / Chief Internal Auditor / Chief Vigilance Officer  
The TA to the Chairman & Managing Director / Director (Generation-Civil) / Director (Distribution, Safety, SCM & IT) / Director (Transmission, SO & Planning) / Director (Generation - Electrical, REES, SOURA, Sports & Welfare)  
The PA to the Director (Finance & HRM)  
The Sr.CA to the Secretary (Administration)  
The RCAO/ RAO  
Stock File.

Forwarded / By Order



Assistant Engineer