



KERALA STATE ELECTRICITY BOARD Ltd

(Incorporated under the Companies Act, 1956)

Registered Office: Vydyuthi Bhavanam, Pattom,

Thiruvananthapuram – 695 004

CIN: U40100KL2011SGC027424

E-mail:ddkseb@kseb.in Website: www.kseb.in

ABSTRACT

Effecting electric connection to Smt.Rajeswari Rajendran, belonging to a BPL category to her house allotted under Life Mission under Electrical Section, Thenmala, Electrical Circle, Kottarakara- Sanctioned - Orders issued.

Corporate Office

B.O. (FTD) No. 35/2024 (KSEBL/DIR/DIST/25/2023-AE2)

Dated:20.01.2024

Thiruvananthapuram

- Read :
1. Letter No. DCE/KTR/AE1/General/23-24/306 dated 06.10.2023 of the Deputy Chief Engineer, Electrical Circle, Kottarakara.
 2. B.O.(FTD) No.261/2022 (D(D&IT)/D4/Service Connection/2021-2/0012) dated 31.03.2022.
 3. Note No KSEBL/DIR/DIST/25/2023-AE2 dated 20.12.2023 of the Director (Distribution, IT, SCM &Safety) to the Full Time Directors.(Agenda No.30-01/2024)

ORDER

The Deputy Chief Engineer, Electrical Circle, Kottarakara as per letter read as 1st above requested sanction for effecting electric connection to Smt Rajeswari Rajendran, belonging to a BPL category under Electrical Section Thenmala, for her house constructed under Life Mission Scheme of the Government. It was further reported that that there is insufficient clearance for providing connection. Aggrieved by this, Smt Rajeswari Rajendran submitted a representation before the Hon'ble Additional District Magistrate, Kollam. The Hon'ble Additional District Magistrate, Kollam has sought a report on the matter with two options for effecting service connection to house of Smt Rajeswari Rajendran.

The first proposal was to draw 32 meter service wire from the post nearby the applicant's house passing through the property of two neighbors, however both the neighbors were unwilling to provide consent for drawing the service wire. Also one of the applicants has filed a petition before the Punalur Municipal Court.

The second proposal includes drawing a LT UG cable through a narrow path having less than 1 meter width towards the house. Since there is less width on the path towards the applicants house and that nearby houses are using iron sheet for covering the house roof and there is insufficient safety clearance with regard to drawing OH bare conductor/LT ABC line for providing connection.


1/19/2024

The Deputy Chief Engineer, Electrical Circle, Kottarakara has reported that an amount of Rs.50,000/- is estimated for drawing LT UG cable and recommended that the same be done using KSEBL's fund considering the poor financial status of the petitioner and also since the petitioner belongs to BPL category.

The matter was circulated among the Full Time Directors as per note read as 3rd above. Having considered the matter in detail, the Full Time Directors, resolved to accord sanction to the Deputy Chief Engineer, Electrical Circle, Kottarakara to effect service connection to Smt.Rajeswari Rajendran, a BPL applicant, to her house allotted under Life Mission under Electrical Section, Thenmala by drawing LT UG cable, using KSEBL's fund, as a special case, considering the poor financial status and that the petitioner belongs to BPL category.

Orders are issued accordingly.

By Order of the Full Time Directors


Lekha G 20/1/2024
Company Secretary

To:

The Deputy Chief Engineer, Electrical Circle, Kottarakara.

Copy to:

The Chief Engineer, Distribution South

The Company Secretary/ Financial Advisor/LA&DEO/ Chief Internal Auditor

The TA to the Chairman & Managing Director / Director (Generation-Civil) /
Director (Distribution, Safety & SCM) / Director (Transmission, SO &
Planning)/ Director (Generation - Electrical, REES, SOURA, Sports &
Welfare)


The PA to the Director (Finance & HRM)

The Sr.CA to the Secretary (Administration)

The RCAO/ RAO

Stock File.

Forwarded / By Order


Assistant Engineer