



# KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Companies Act, 1956)

Reg. Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004

CIN:U40100KL2011SGC027424 Website: [www.kseb.in](http://www.kseb.in)

Phone: +91 471 2514685, 2514331, Fax: 0471 2447228 E-mail: [ddkseb@kseb.in](mailto:ddkseb@kseb.in)



## Abstract

Temporary SOP to Adlux Exhibition Centre, Karukutty in favour of the Tahasildar(LR), Aluva Taluk under Electrical Section, Karukutty for the functioning of Covid-19 Second Line Treatment Centre – Action ratified – Orders issued

## CORPORATE OFFICE (SBU-D)

**B.O.(FTD) No. 552/2021 (D(D&IT)/D-2/SOP/0015/20-21 Dated, Thiruvananthapuram, 15.07. 2021**

Read: 1. Letter No. CE(DC)/AEE2/HT General/ 2021-22/748 dated 16.06.2021 of the Chief Engineer, Distribution (Central), KSEBL, Ernakulam

2. Note No D(D,IT &HRM)/ D2/SOP/0015//20-21 dated 01.07.2021 of the Director (Distribution. IT & HRM) to the Full Time Directors (Agenda No. 13/7/21)

## ORDER

The Chief Engineer Distribution Central, as per the letter read as 1<sup>st</sup> above, has intimated that the Deputy Chief Engineer, Electrical Circle, Perumbavoor has given a temporary HT service connection to Adlux Exhibition Centre, Karukutty in favour of the Tahasildar (LR), Taluk Office, Aluva under Electrical Section, Karukutty, for the functioning of Covid- 19 Second Line Treatment Centre and ratification is sought on his action.

The Tahasildar(LR), Aluva, had requested to provide an electric connection to cater 300kVA power to the exhibition centre at Adlux, Karukutty for a Covid-19 Second Line Treatment Centre. As per the order of the Divisional Magistrate, Fort Kochi, the Tahasildar(LR), Aluva, was entrusted to obtain power connection and to take over the premises. The treatment centre is supposed to operate for two months. M/s. Adlux is having an HT connection at their premises, but this HT connection is not extended to the exhibition centre and so a separate connection was requested. Hence, an estimate was prepared for a temporary connection (for two months) as envisaged vide Kerala Supply Code 2014 regulation 88 which details the procedure for providing temporary connection. The ECSC charges of the estimate comes to Rs. 5,30,957/-. The work includes extending 360mtrs of 11kV OH line, installation of a 990kVA CSS, associated cabling and erection of HT metering equipments. The amount includes the rental charges for two months period, labour and transportation charges, supervision charges, testing fees, GST @ 18%.

The security amount for two months current charges is estimated to Rs.10,56,000/- (Rupees Ten Lakhs Fifty Six Thousand only) with the assessment of 48000 units per month.

The ratio of CT/PT unit connected is 200/5A of 0.5S class instead of 20/5A. The tariff assigned to the connection is HT VII which is applicable to temporary connections.

The Chief Engineer Distribution(Central) has also pointed out that, previously on 07.06.2020, a temporary HT service connection was given to M/s. Adlux Exhibition Centre, Karukutty in favour of the Tahasildar, for functioning of Covid First Line Treatment Centre (LCN 6/9289) and it was dismantled on 25.01.2021. The total demand against this connection was Rs.7,91,987/- towards ECSC charges and Rs.39,07,319/- as CC arrear. On 30.03.2021, the ECSC charges of Rs.7,91,987/- was remitted. But the CC arrear of Rs.39,07,319/- is still pending. The Tahasildar assured to remit the amount as and when they received the fund from Government.

Considering the social obligation and Covid crisis, all the works has been completed from KSEBL side on 26.05.2021 for effecting the supply to Adlux Exhibition Centre, Karukutty in favour of the Tahasildar(LR), Aluva. The HT agreement had been executed and also the temporary service connection was effected on 28.05.2021.

Hence, the Chief Engineer Distribution(Central) has requested ratification of the full Time Directors in the action of the Deputy Chief Engineer, Electrical Circle, Perumbavoor .

The matter was placed before the Full Time Directors as per note read as 2<sup>nd</sup> above.

Having considered the matter in detail, the Full Time Directors in the meeting held on 12.07.2021, resolved to ratify the action of the Deputy Chief Engineer, Electrical Circle, Perumbavoor in having effected temporary HT service connection to the extent of 300kVA to Adlux Exhibition Centre, Karukutty in favour of Tahsildar (LA), Taluk Office, Aluva at HT VII tariff for functioning as Second level treatment Centre of Covid 19 under Electrical Section Karukutty, without payment of ECSC charges, security deposit and without realizing the pending arrear amount of Rs.39,07,319/- and in having provided metering with higher capacity CT with less accuracy class in the exigency of Covid 19 Pandemic.

Further resolved to direct the Deputy Chief Engineer, Electrical Circle, Perumbavoor to replace the CT with required ratio at the earliest and to take up the matter of remitting the pending amount including the arrears with the Tahsildar (LA), Aluva

Orders are issued accordingly.

By Order of Full Time Directors,  
Sd/-  
Lekha G.  
Company Secretary (In charge)

To

The Deputy Chief Engineer, Electrical Circle, Perumbavoor  
The Special Officer (Revenue)

Copy to:

The Chief Engineer (Distribution Central), Ernakulam/The Chief Engineer (IT&CR)  
The Financial Adviser/The Chief Internal Auditor/Company Secretary  
The RCAO/The RAO/The LLO  
The TA to Chairman & Managing Director/The TA to Director (Distribution, IT & HRM  
/ Transmission, System Operation/ Generation-Electrical & Supply Chain Management /  
Generation-Civil/Planning & safety)  
The PA to Director (Finance)/ Senior CA to Secretary (Administration)  
The Fair Copy Superintendent/Library/Stock File

Forwarded/By Order



Assistant Executive Engineer