



KERALA STATE ELECTRICITY BOARD Ltd

(Incorporated under the Companies Act, 1956)

Registered Office: Vidyuthi Bhavanam, Pattom,

Thiruvananthapuram – 695 004

CIN: U40100KL2011SGC027424

Website: www.kseb.in

ABSTRACT

Palivasal HEP - Request for total shutdown from 10.02.2023 to 03.03.2023 - Sanction accorded - Orders issued.

Corporate Office (SBU-G/E)

BO (FTD)No.70/2023(DGE/G3/Pallivasal Shutdown) /1286

Thiruvananthapuram, Dated: 13.02.2023

Read: 1. Letter No.CEG/AEE-VII/PLVSL/GNL/2022-23/1487 dated 20.01.2023 of the Chief Engineer (Generation), Moolamattom.
2. Note No. DGE/G3/Pallivasal SD /2022-23 /1225 dated 02.02.2023 of the Director (Gen.-Ele. &HRM) to the Full Time Directors(Agenda item No.7/2/23).

ORDER

The Chief Engineer (Generation) as per the letter read as 1st above has requested sanction for availing total shutdown of Pallivasal HEP with effect from from 10.02.2023, 08:00 hrs to 03.03.2023, 17:00 hrs., for carrying out the leakage rectification works in all the three shutters of RA Head works.

The water to the Pallivasal HEP is diverted through the diversion weir (RA Head works) in Mudirappuzha river. The weir has three shutters each of which have severe leakage through the side and bottom which has already affected the generation of Pallivasal Power station. Also, the leakage has to be rectified before commissioning of the on going Pallivasal Extension Scheme Power House (PES).

In the above circumstances, the Chief Engineer (Generation) has requested for the shutdown of Pallivasal HEP.

The matter was placed before the Full Time Directors as per the note read as 2nd above.

Having considered the matter in detail, the Full Time Directors meeting held on 06.02.2023 resolved to accord sanction for the total shutdown of the Pallivasal HEP with effect from 10.02.2023, 08:00 hrs to 03.03.2023, 17:00 hrs, for carrying out the leakage rectification works in all the three shutters of RA Head works.

further resolved that the Director (Generation-Electrical) and Director (Generation-Civil) shall conduct a joint study on maintenance of all power stations and prepare a manual/ maintenance schedule in this regard.

Orders are issued accordingly.

**By Order of the
Full Time Directors**

Sel/-


**LEKHA G
Company Secretary**

To:

The Chief Engineer (Generation), Moolamattom.

Copy to: The Financial Adviser/ Chief Internal Auditor/ Company Secretary
The Deputy Chief Engineer, Generation Circle, Meencut.
The TA to CMD/ D(GE&HRM)/ D(T, SO, P&S)/ D(D,IT&SCM)/ D(GC)/ D(R,S,N,S&W)
The PA to D(F)
Stock File.

Forwarded / By Order



Assistant Executive Engineer