



## KERALA STATE ELECTRICITY BOARD Ltd

(Incorporated under the Companies Act, 1956)

Registered Office: Vydyuthi Bhavanam, Pattom,

Thiruvananthapuram – 695 004

CIN: U40100KL2011SGC027424

Website: www.kseb.in

Phone: +91 471 2514576, 2446885, 9446008884

Email: dtkseeb@kseeb.in

### ABSTRACT

Requesting sanction for 50% advance payment to CPRI for the work "onsite de-chlorination of PCB contaminated transformer oil using CPRI mobile de-chlorination unit at 220kV Substation Nallalam" - Sanction accorded - Orders issued.

### Corporate office (SBU-T)

BO (FTD) No.58/2023(DIRTSO-AE1/2022/3061)

Thiruvananthapuram, Dated: 07.02.2023

Read: 1. Letter No. CE/TRN/E6/220kV Nallalam De-chlorination/2022-23/1973 dated 22.01.2023 of the Chief Engineer (Transmission North).  
2. Note No. DIRTSO-AE1/2022/3061(1) dated 17.01.2023 of the Director (T,SO,P&S) to the Full Time Directors (Agenda 55/1/23).

### ORDER

Administrative sanction was accorded by the Chief Engineer (Transmission North) for an estimate amounting to Rs.42 Lakh for the work "onsite de-chlorination of PCB contaminated transformer oil contained in 5 nos of GE make 220/110kV, 20MVA single phase transformer using mobile de-chlorination unit at 220kV Substation Nallalam".

The Central Power Research Institute (CPRI) is the only authorised agency in the country for the de-chlorination process. Hence sanction was accorded by the Chief Engineer for an estimate amounting to Rs.32,16,019/- as per the quotation received from CPRI. 50% advance payment was requested by CPRI for carrying out the work.

The total quantity of oil for onsite de-chlorination including flushing of transformer is 1,36,272 ltr. The de-chlorination work is scheduled to be conducted from 17.02.2023 to 05.05.2023, total 65 days required to complete the work.

In order to issue work order to CPRI and to complete the work within the scheduled time, the Chief Engineer (Transmission North) as per letter read as 1<sup>st</sup> above requested sanction for making 50% advance payment amounting to Rs.16,08,010/- to CPRI.


The matter was placed before the Full Time Directors as per note read as 2<sup>nd</sup> above. Having considered the matter in detail, the Full Time Directors in the meeting held on 31.01.2023,

Resolved to accord sanction to the Chief Engineer (Transmission North) for issuing work order to CPRI for an amount of Rs.32,16,019/- by accepting their payment condition of 50% advance payment amounting to Rs.16,08,010/- for carrying out the work "onsite de-chlorination of PCB contaminated transformer oil using CPRI mobile de-chlorination unit at 220kV Substation, Nallalam".

Further resolved that the Directors shall take initiative to complete scrap disposal in next three months.

Orders are issued accordingly.

**By Order of the  
Full Time Directors**



**LEKHA G  
Company Secretary**

To:

The Chief Engineer (Transmission North).

Copy to: The Financial Advisor/ Chief Internal Auditor/ Company Secretary/ Chief Engineer (IT, CR & CAPs)

The Deputy Chief Engineer, Transmission Circle, Kozhikode.

The TAs to CMD/ D(T,SO,S&P)/ D(D,SCM&IT)/ D(G-C), D(G-E&HRM)/


D(REES,S&W)

The PA to Director (Finance)

The Sr. CA to Secretary (Administration)

Stock file

Forwarded / By Order



Assistant Engineer