



KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Companies Act, 1956)

Reg. Office: Vydyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004

CIN:U40100KL2011SGC027424 Website: www.kseb.in

Phone: +91 471 2514685, 2514331, Fax: 0471 2447228 E-mail: ddkseb@kseb.in

ABSTRACT

Effecting service connection to Oxygen Plant in LT in favour of the Superintendent, District Hospital, Tirur under Electrical Section Tirur West - Sanctioned - Orders issued.

CORPORATE OFFICE (SBU-D)

B.O(FTD) No. 505 /2021 (D(D&IT)/D4/General/2021-22/0013)Dated.Tvpm. 02.07.2021.

Read:- 1.Letter No.DB17/Deemed HT/2021-22/287 dated 01.06.2021 of the Deputy Chief Engineer,Electrical Circle, Tirur.

2.Note No.(D(D&IT)/D4/General/2021-22/0013)/dated 18.06.2021 of the Director (Distribution,IT & HRM)(Agenda Item No 81/6/21).

ORDER

The Deputy Chief Engineer has reported as per letter read as 1st above that the Superintendent, District Hospital, Tirur requested for obtaining electricity connection to the newly proposed Oxygen Plant at District Hospital Tirur which is sanctioned under PM care Fund as a part of defending the Covid 19 pandemic. The proposed connected load of the plant is 150 kW to 200 kW. But the applicant wants to avail the connection in LT with deemed HT status at the earliest as the Covid-19 pandemic persists severely in Malappuram District.

The Superintendent, District Hospital, Tirur further intimated that they will take necessary steps to avail the connection in HT within 6 months.

The Deputy Chief Engineer requested to accord necessary sanction in order to effect the service connection in LT with deemed HT status instead of HT for a period of six months.

As LT connection billing for contract demand above 100 kVA is not incorporated in ORUMANET, billing may have to be done as Ex. system.

The matter was placed before the Full Time Directors as per note read as 2nd above.

Having examined the matter in detail, the Full Time Directors in the meeting held

on 24.06.2021 resolved to accord sanction to the Deputy Chief Engineer, Electrical Circle, Tirur to effect the service connection to Oxygen Plant in favour of Superintendent, District Hospital, Tirur under Electrical Section Tirur West in Deemed HT for a period of six months due to Covid pandemic as a special case, subject to the condition that the connection shall be converted to HT after six months or the end of Covid pandemic and the requirement of treatment of covid patients is over whichever is earlier.

Further resolved to authorize the Assistant Engineer, Electrical Section, Tirur West to issue Ex.system bill to the consumer as the connection is in Deemed HT.

Orders are issued accordingly.

By Order of the Full Time Directors

Sd/-

Lekha G.

Company Secretary (In charge)


To

The Deputy Chief Engineer, Electrical Circle, Tirur.

Copy to:

The Chief Engineer Distribution North /Chief Engineer (IT & CR)/Vigilance Officer/Legal Advisor & Disciplinary Enquiry Officer/
Chief Internal Auditor/Financial Adviser
The TA to Chairman & Managing Director
The TA to Director (Distribution, IT & HRM / Planning, Safety & REES/Generation-
Electrical, & SCM/ Transmission & System Operation / Generation- Civil)
The RAO/ECA/RCAO/The Legal Liaison Officer
The PA to Director (Finance) / C.A. to Secretary (Administration)/
Company Secretary
Fair Copy Section / Library / Stock File

Forwarded / By Order


Asst. Executive Engineer