



KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Companies Act, 1956)

Reg. Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004

CIN:U40100KL2011SGC027424 Website: www.kseb.in

Phone: +91 471 2514685, 2514331, Fax: 0471 2447228 E-mail: ddkseb@kseb.in

ABSTRACT

Effecting service connection to Oxygen Plant in LT in favour of Sri.Prathapan KM, Managing Partner, M/s Southern Air Product Maravattom under Electrical Section Kottakkal - Sanctioned - Orders issued.

CORPORATE OFFICE (SBU-D)

B.O(FTD) No.500/2021 (D(D&IT)/D4/General/2021-22/0011)Dated.Tvpm. 01.07.2021.

Read:- 1.Letter No.DB17/Deemed HT/2021-22/198 dated 21.05.2021 of the Deputy Chief Engineer,Electrical Circle, Tirur.

2.Note No.(D(D&IT)/D4/General/2021-22/0011)/dated 23.06.2021 of the Director (Distribution,IT & HRM)(Agenda Item No 83/6/21).

ORDER

The Deputy Chief Engineer,Electrical Circle,Tirur reported as per letter read as 1st above that Sri.Prathapan KM, Managing Partner,M/s Southern Air Product Maravattom requested for obtaining service connection to the newly proposed oxygen plant Maravattom, fag end of Parappur 11kV feeder from 110kV substation Edarikkode. The expected connected load of the plant is 166 kVA (200 HP) and the applicant requested to avail the service connection in LT. Also the applicant has requested to utilize the 250 kVA transformer already available under his custody for the venture. The 160 kVA transformer already installed at the locality is being shared by many consumers and is already having reasonable load. Enhancing the 160 kVA transformer to 250 kVA transformer will not serve the purpose. New 250 kVA transformer has to be installed to grant service connection to the proposed oxygen plant.

The applicant is not willing to invest HT connection expenses right now as the plant is supposed to operate till Covid situation is improved.

The Chairman and Convener,Oxygen Management Committee under the District Collectorate also requested to grant the service connection to the proposed private Oxygen Plant in LT instead of HT. Also as no ECSC rate is available for LT connection above 100 kVA contract demand,the applicant is supposed to

of the Electrical Wiring Scheme from the Electrical Inspectorate. Fixing CTs, energy meter and giving connection to the premises will come under the scope of KSEBL. The cost of providing DP structure with AB has to be remitted by the party.

As LT connection billing for contract demand above 100 kVA is not incorporated in ORUMANET, billing may have to be done as Ex system.

Considering the emergent covid related situation that necessitated the availability of Medical Oxygen to various hospitals including that to District and Taluk Hospitals, the proposal was processed, without waiting for document procedures. The work was carried out and connection (Con.No. 1165571050750) effected on 13.05.2021 (Con.No 1165571050750) with a total connected load of around 160 kW.

The matter was placed before the Full Time Directors as per note read as 2nd above.

Having examined the matter in detail, the Full Time Directors in the meeting held on 24.06.2021 resolved to ratify the action of the Deputy Chief Engineer, Electrical Circle, Tirur in effecting the service connection to Oxygen Plant in favour of Sri.Prathapan K M, Managing Partner, M/s Southern Air Product Maravattom under Electrical Section Kottakkal in Deemed HT for a period of six months as per the request of the applicant and due to Covid pandemic as a special case, subject to the condition that the connection shall be converted to HT after six months or the end of Covid pandemic and the requirement of treatment of covid patients is over whichever is earlier.

Further resolved to authorize the Assistant Engineer, Electrical Section, Kottakkal to issue Ex, system bill to the consumer as the connection is in Deemed HT.

Orders are issued accordingly.

By Order of the Full Time Directors

Sd/-

Lekha G.

Company Secretary (In charge)

To

The Deputy Chief Engineer, Electrical Circle, Tirur.

Copy to:

The Chief Engineer Distribution North /Chief Engineer (IT & CR)/Vigilance Officer/Legal Advisor & Disciplinary Enquiry Officer/
Chief Internal Auditor/Financial Adviser
The TA to Chairman & Managing Director
The TA to Director (Distribution, IT & HRM / Planning & Safety / Generation-
Electrical, & SCM/ Transmission & System Operation / Generation- Civil)
The RAO/ECA/RCAO/The Legal Liaison Officer
The PA to Director (Finance) / C.A. to Secretary (Administration)/
Company Secretary
Fair Copy Section / Library / Stock File

Forwarded / By Order



Asst. Executive Engineer