



KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Companies Act, 1956)

Reg. Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004

CIN:U40100KL2011SGC027424 Website: www.kseb.in

Phone: +91 471 2446885, Fax: +91 471 2444738 E-mail: dtkseb@kseb.in

ABSTRACT

Deposit works in favour of M/s.KMRL for raising the height of EHT line crossing Metro phase 2 alignment – Batch 2 under Transmission Circle, Kalamassery Administrative sanction accorded- Orders issued.

Corporate Office(SBU-T)

B.O(FTD)No.113/2021/D(T&SO)/T3/klsy/KMRL/2020-21

Dated TvpM 08.02.2021

Read: 1. Note no.CE(TS) EE1/AEEII/kalamassery/KMRL/2020-21/1277/30.12.2020 of the Chief Engineer (Transmission)

2. Note No. D (T&SO)/ T3/ Klsy/KMRL/ 2020-21/247 Dated: 29.01.2021 of the Director (T&SO) (Agenda No. 1/2/21)

ORDER

M/s.KMRL is progressing with Phase II of the Metro alignment works. Now they have requested to increase the clearance of 66 kV EHT line crossing the proposed track Hence the Chief Engineer, Transmission South as per Note read as 1st above,has submitted a proposal for inserting 5 nos. towers in 3 feeders and dismantling 5 nos. existing towers for increasing the clearance of the EHT line crossing to the proposed track under deposit work .

The following works are included in the proposal.

Sl. No	Description of work	Tower Insertion	Tower Dismantling	Estimate Amount (Rs)	Supervision Charges to be collected from KMRL(including GST) (Rs.)
1 .	Raising height of 110kV Kalamassery – Vytilla feeder at Vazhakkala between location 25&26 to 32.1m above ground level.	2 nos. of 110kV 'C' type narrow based tower.	3 Nos. 'D3' tower at location 25,26 & 27	2,80,10,000	25,45,967/-
2	Raising height of 110kV Kalamassery – Aroor feeder to 32.1m above ground level at Vazhakkala between location 35 & 36.	1 no. of MCMV KLD type tower with 9m extension & 1 no. 110KV DC 'C' type narrow based tower	220kV 'P' type Tower – 1 no.	4,77,60,000	43,41,727/-
3	Raising height of 220kV Cochin – Kalamassery feeder near infopark policestation (location 30 & 31) to 25.4m above ground level.	1no. MCMV KLD (Narrow based tower) with 9m extension & 1 no. 220KV DC 'R' type narrow based tower with 6m extension.	220kV 'P' type tower – 1no. At location 30.	4,45,50,000	40,49,358/-
Total				12,03,20,000	1,09,37,052/-

The estimates are prepared based on transmission cost data dated 24.04.2019 and labour data for Transmission Line construction dated 13.04.2020 and civil data based on DSR 2016.

The Total estimate amount is Rs. **12,03,20,000/-**

The work is envisaged to be executed with material supply and work both being carried out by KMRL under the supervision of KSEB Ltd. The supervision charges amounting to Rs. 1,09,37,052 and all other statutory expenses for the work are to be borne by M/s KMRL.

As per the Clause no. 8.1 of Delegation of powers of Executive officers dated 25.04.2017 , the Full Time Director is authorised to grant administrative sanction to Deposit works > Rs. 5 Cr.

The matter was placed before the Full Time Directors as per note read as 2rd above .

Having considered the above, the Full Time Directors in the meeting held on 04.02.2021,

Resolved to accord Administrative Sanction for an amount of Rs. 12.032 Crore (Rupees Twelve Crore three lakh and twenty thousand) in favour of M/s KMRL under Transmission Circle, Kalamassery for inserting 5 nos. towers in 3 feeders and dismantling 5 nos. existing towers for increasing the clearance of the EHT line crossing to the proposed track of Phase II of the Metro alignment works under deposit work under Transmission Circle, Kalamassery, subject to condition that the supervision charges amounting to Rs. 1,09,37,052/- and all other statutory expenses for the work are to be borne by M/s KMRL.


Orders are issued accordingly.

By order of the Full Time Directors,
Sd/-
Lekha G.
Company Secretary (In- Charge),

To,
The Chief Engineer (Transmission South).

Copy to:

The Deputy Chief Engineer, Transmission Circle , Kalamassery.
The Deputy Chief Engineer (IT)
The Financial Adviser/ The Chief Internal Auditor/ The RCAO/ RAO.
The TA to Chairman & MD/ D(T&SO/D(D&HRM)/D(G-C)/ D(G-E&SCM)/D(P&S)
The PA to Director (Finance)/CA to Company Secretary
Fair Copy Superintendent/Library/Stock File.

Forwarded / By Order

Assistant Executive Engineer