

Abstract

Laying 11kV 3X300sq mm UG cable (4 run) from Josco Automobiles upto NH(Cochin Port Area) under Electrical Section, Palluruthy in connection with the power evacuation from 110kV substation, Kattaribagh- request for accepting single tender after retendering– Sanction Accorded – Orders issued

CORPORATE OFFICE (SBU-D)**B.O.(FTD) No.42 /2021 (D(D,IT&HRM) /D-2/ Tender/ 003/ 2020-21 Dated, TVPM, 19 .01. 2021**

Read: 1. Letter No. CEDC/ AEE1/PMU/20-21/2456 dated 04.12.2020 of the Chief Engineer

(Distribution Central), Ernakulam

2. Note No D(D,IT &HRM))/ D2/Tender/Palluruthy/003//20-21 dated 24.12.2020 of the Director (Distribution, IT & HRM) to the Full Time Directors (Agenda No. 03/01/21)

ORDER

The competitive E-tenders were invited by the Executive Engineer, Project Management Unit, Ernakulam for the work of laying 11kV 3X300 sqmm UG cable (4 run) from Josco Automobiles upto NH(Cochin Port Trust Area) under Electrical Section, Palluruthy, in connection with power evacuation from 110kV Substation, Kattaribagh, with a PAC of Rs.69,32,216/-, after giving wide publicity as per norms.

The last date of online submission was on 25.09.2020 and date of opening of prequalified bids was on 30.09.2020. But, only one bid was received within the stipulated time. Hence, the last date of online submission was extended upto 09.10.2020 and there was no more response during the extended period. Hence, the work was re-tendered with the last date of online submission on 31.10.2020 and the date of opening of pre qualified bids on 05.11.2020.

Only one tender was received after retendering. Hence, the same was opened on 05.11.2020. The tender was quoted by M/s. Lijo Poulouse Company, Thettayil House, Edanad Sreemoolanagaram, Ernakulam at 14.5% above the PAC rate. The rock bottom rate was sought from the bidder and after negotiation, the firm has reduced the rate and agreed to carry out the work @ 1% below estimate rate. On further negotiation by the Chief Engineer Distribution (Central), the bidder has reduced the rate to 1.5% below the estimate rate.

The 110kV substation, Kattaribagh is under loaded as two major 11kV feeders viz. Cochin Port & Bristaw was released by Cochin Port as they availed 110kV supply. The 11KV feeders Vathuruthy and Pyari became faulty in Cochin Port area and are in irreparable condition. Palluruthy area under Electrical Division, Mattancherry is the tail end of three substations viz. Chellanam, Aroor and Mattancherry and is experiencing severe power shortage

Substation in an alternate route for effective utilization of the substation. Two feeders are proposed for Palluruthy area and one feeder to Thoppumpady area. The works involves construction of 1.2km Underground duct at edge of pavement, duct size 1m x1m (inside dimensions) lined with RCC-20 cm thick and covered with RCC slab of 10cm thickness on urban roads, providing clamps in 50cms intervals for mounting cable including fitting accessories. 4 runs of UG cable is to be drawn in the duct viz. two runs at the clamps provided in the duct and two runs on the bottom of the duct after spreading fine sand.

It is also reported that approval has been received from M/s. Cochin Port Trust for laying 11kV 3x300sqmm UG cable through the property of Cochin Port Trust. Hence the work has to be carried out urgently. Hence, sanction is requested for awarding the work of laying 11kV 3X300 sqmm UG cable (4 run) from Josco Automobiles upto NH (Cochin Port Area) under Electrical Section, Palluruthy to M/s. Lijo Poulouse company, Ernakulam at his rock bottom rate of 1.5% below estimate rate.

The matter was placed before the Full Time Directors as per note read as 2nd above.

Having considered the matter in detail, the Full Time Directors in the meeting held on 07.01.2021, resolved to accord sanction to the Deputy Chief Engineer, Electrical Circle, Ernakulam for accepting single tender for the work of laying 11kV 3X300 sqmm UG cable (4 runs) from Josco Automobiles upto NH (Cochin Port Area) under Electrical Section, Palluruthy and to issue work order to the single tenderer M/s. Lijo Poulouse company, Thettayil House, Edanad, Sreemoolanagaram, Ernakulam at his quoted rock bottom rate of 1.5% below estimate rate.

Orders are issued accordingly.

By Order of Full Time Directors,
Sd/-
Lekha G.
Company Secretary (In charge)

To

The Deputy Chief Engineer, Electrical Circle, Ernakulam

Copy to:

The Chief Engineer (Distribution Central), Ernakulam/The Chief Engineer (IT&CR)

The Financial Adviser/The Chief Internal Auditor/Company Secretary

The RCAO/The RAO/The LLO

The TA to Chairman & Managing Director/The TA to Director (Distribution, IT & HRM / Transmission, System Operation/ Generation-Electrical & Supply Chain Management / Generation-Civil/Planning & safety)

The PA to Director (Finance)/ Senior CA to Secretary (Administration)

The Fair Copy Superintendent/Library/Stock File

Forwarded/By Order