



KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Companies Act, 1956)

Reg. Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004

CIN:U40100KL2011SGC027424 Website: www.kseb.in

Phone: +91 471 2514685, 2514331, Fax: 0471 2447228 E-mail: ddkseb@kseb.in



Abstract

Petition received from Sri. Abdul Rasheed, Chittothayil House, Pallam, Thrissur in Santhwanasparsham Adalath – Shifting of line – Sanction Accorded – Orders issued

CORPORATE OFFICE (SBU-D)

B.O.(FTD) No.309/2021 (D(D&IT)/D-2/Santhwanasparsham/0003/2021-22 Dated, TVPM, 05.05. 2021

- Read: 1. Letter No. GB1/Adalath-Santhwanasparsham 2020-21/1779 dated 09.03.2021 of the Deputy Chief Engineer, Electrical Circle, Thrissur
2. Note No D(D,IT &HRM))/ D2/Santhwanasparsham/0003//21-22 dated 09.04.2021 of the Director (Distribution, IT & HRM) to the Full Time Directors (Agenda No. 31/04/21)

ORDER

A Petition was received from Sri. Abdul Rasheed, Pallam, in the Santhwanasparsham Adalath 2021 held on 02.02.2021 at Thalappalli Taluk, for shifting of a 3 phase 4 wire line crossing over his building. Thereupon, direction was issued to give the concession given in the Adalath conducted in 2020.

The Executive Engineer (incharge), Electrical Circle, Thrissur, as per letter read as 1st above, has forwarded an estimate, prepared by the Assistant Engineer, Electrical Section, Desamangalam, amounting to Rs.16,616/- for the above work and has requested for sanction of 25% concession on the estimate amount as per the Adalath guidelines 2020, for the execution of the works.

As per the report of the Assistant Engineer, Electrical Section, Desamangalam, it is learnt that, prior to the Santhwanasparsham Adalath, a petition was received from Sri. Abdul Rasheed for shifting of the line. Accordingly, an estimate was prepared. But it was informed that he was unable to remit the money. Hence, considering the safety, a post was inserted in the line and the line was lifted to a certain extend. But still the line was very close to the roof of his house.

Moreover, this line is passing over the house of 4 other persons. Further, there are a lot of coconut trees on its path. The fall of coconut leaves on the line is also frequent.

The matter was placed before the Full Time Directors as per note read as 2nd above.

Having considered the matter in detail, the Full Time Directors in the meeting held on 16.04.2021 resolved to accord sanction to the Deputy Chief Engineer, Electrical Circle, Thrissur to issue 25% concession on the estimate amount of Rs.16,616/-, as per the Adalath guidelines 2020, for the execution of the work of dismantling the line passing through the property of the petitioner Sri. Abdul Rasheed and drawing 40 meters single phase OH line, considering safety aspects .

Orders are issued accordingly.

By Order of Full Time Directors,
Sd/-
Lekha G.
Company Secretary (In charge)

To

The Deputy Chief Engineer, Electrical Circle, Thrissur

Copy to:

The Chief Engineer (Distribution Central), Ernakulam/The Chief Engineer (IT&CR)
The Financial Adviser/The Chief Internal Auditor/Company Secretary
The RCAO/The RAO/The LLO
The TA to Chairman & Managing Director/The TA to Director (Distribution, IT & HRM /
Transmission, System Operation/ Generation-Electrical & Supply Chain Management /
Generation-Civil/Planning & safety)
The PA to Director (Finance)/ Senior CA to Secretary (Administration)
The Fair Copy Superintendent/Library/Stock File

Forwarded/By Order



Assistant Executive Engineer