



KERALA STATE ELECTRICITY BOARD Ltd

(Incorporated under the Companies Act, 1956)

Registered Office: Vydyuthi Bhavanam, Pattom,

Thiruvananthapuram – 695 004

CIN: U40100KL2011SGC027424

Website: www.kseb.in

Phone: +91 471 2514685, 2514331

Email: ddkseb@kseb.in

ABSTRACT

Tribal Colony Electrification - Fund requirement - Further action -sanctioned- orders issued

Corporate Office (SBU-D)

BO (FTD)No.99/2023(D(D&IT)/D6-AE1/General/Colony Thiruvananthapuram,Dated: 01.03.2023
Electrification/2021-22 /)

- Read: 1. Minutes of meeting dated 24.11.2022 between the Hon'ble Minister for Electricity & Hon'ble Minister for Devasom & Backward Class Development Department.
2.Letter no.CAPs/RDSS/AE1/2022-23/604 dated 29.11.2022.
3. Decision of the meeting dated 06.02.2023 between the Hon'ble Minister for Electricity & Hon'ble Minister for Devasom & Backward Class Development Department.
4. Note no.D(D&IT)/D6-AE1/General/Colony Electrification/2021-22(22) dated 07.02.2023 of the Director (D, IT &SCM) to the Full Time Directors (Agenda item no.29/02/2023).

ORDER

As per the decision of the Government to provide electricity to all Tribal colonies within 6 months, KSEBL identified 64 tribal colonies without electricity, where grid supply could not be provided due to high capital investment involved and the requirement of sanction from Forest Department.

KSEBL later updated the un-electrified colony list by including the list of colonies provided from Tribal Department and other tribal offices and as of now, the number of un-electrified colonies stands at 101 Nos. Out of this, grid extension is possible in 65 colonies. The grid electrification is now completed in 8 colonies and solar electrification in 1 colony. Also grid extension work is in progress for another 9 colonies and expected to be completed before May 2023.

Based on the decision of the Minister level meeting dated 05.07.2022 and considering the relocation of colonies in Wayanad District, there is change in the number of colonies feasible for grid extension and colonies proposed for solar electrification. At present the number of 'grid connection possible colonies' without fund is 25 Nos and the amount required for electrifying these colonies is Rs.24.26 Crore. The colonies proposed for solar electrification is 38 nos.

As per the minutes read as 1st above, it was decided to complete the electrification of tribal colonies within 31st March 2023, by including the same in RDSS project. Accordingly, as per letter read as 2nd above, M/s PFC was requested to intimate the possibility of getting additional sanction for the electrification works of tribal colonies along with the already sanctioned DPR for Phase-1 of RDSS, so as to complete the works before 31.03.2023. Since the chance of sanctioning the entire fund in RDSS based on the present guideline is low, in the joint meeting held on 06.02.2023 by the Hon'ble Minister for Electricity and the Hon'ble Minister for welfare of Backward and Scheduled Communities, it was decided that only 20% of the estimate amount shall be made available to KSEBL from ST Department and

the balance fund shall be arranged by KSEBL.

As per clause 28 of Supply code 2014 "In case the supply of electricity is sought in a village, hamlet or area wherein no provision for supply of electricity exists, the licensee shall take up the electrification of such locality as per the investment plan approved by the Commission. Once electrification of such locality is completed, supply shall be provided to the applicant in accordance with the provisions of this Code".

As per MYT proposal of KSEBL, an amount of Rs.100 crore has been set apart for continued electrification but the same has not yet been approved by the Hon'ble Commission.

The matter was placed before the Full Time Directors as per the note read as 4th above.

Having considered the matter in detail, the Full Time Directors in its meeting held on 17.02.2023 observed that the ST Department has assured 20% amount. It was also observed that the estimate shall vary and if so the variation shall be reported; however, KSEBL should go ahead as decided in the meeting held on 06.02.2023 by Hon'ble Minister (Power) and Hon'ble Minister (SC/ST Welfare).

The Full Time Directors resolved to accord sanction for the following.

1. To request ST Department to release 20% of estimate cost of Rs.24.26 crore required for grid electrification of 25 Nos. of ST colonies (for which funds are not presently available) urgently, as decided in the meeting held on 6.02.2023.
2. To authorize Chief Engineer (Commercial & Tariff) to file a separate petition for including 80% of total cost of electrification of 25 tribal colonies in the MYT Plan 2022-27 of Distribution, as per clause 28 of Supply code 2014.
3. To arrange the estimated cost of Rs.24.26 Crore required for grid electrification of 25 Nos. of ST colonies from Rs.100 Crore set apart for continued electrification in the MYT Plan 2022-27 of Distribution wing in anticipation of getting 20% of estimated cost from ST Department and approval from Hon'ble KSERC for including the balance 80% in the MYT Plan 2022-27 of Distribution.
4. To authorize the concerned Deputy Chief Engineers to carry out the works using KSEBL own fund, as a special case.

Orders are issued accordingly.

**By Order of the
Full Time Directors**

Sd/-


**LEKHA G
Company Secretary**

To:

- 1.The Chief Engineers Distribution
- 2.The Chief Engineer (Commercial & Tariff)
- 3.The Deputy Chief Engineers, Electrical Circle Pathanamthitta, Thodupuzha, Palakkad, Shornur and Nilambur

Copy to: The Chief Engineer (IT ,CR&CAPs)/ Financial Advisor/ Chief Internal Auditor/
Company Secretary/LA &DEO/CVO/CPRO
The TA to (CMD/Director (G-C)/ Director (G-E&HRM)/ Director(T ,SO, P &S)/
Director(D, IT &SCM) /Director (REES, Soura, NILAAVU, S &W)
The PA to Director (Finance)
The RCAO/RAO/LLO/Special Officer Revenue
The Sr. CA to Secretary (Administration)
Stock file.

Forwarded / By Order


Assistant Engineer

Details of unelectrified ST colonies

List of colonies

Electrical Circle	SI no.	Name of Colony	Quantum of work for grid extension	No. of Houses	Estimate Amount
Pathanamthitta	1	Laha Manjathod	Construction of 600mtr LT ABC 3x95 sqmm+ 1x70 Sqmm using 8mtr PSC poles and 100mtr LT ABC 3x50+1x35sqmm.	43	812910
Thodupuzha	2	Mangappara	DRAWING 2300 MTR 3PH ABC	40	1162751
	3	Puthukudy	DRAWING 1900 MTR 3PH ABC	30	1508917
	4	Puravayal kudi	Laying 1.60km 11 KV UG Cable installing 100kva DTR, 60 mtr 3ph and 300mtr 1ph	25	3134000
	5	Iruttala kudi	Laying 850mtr 11 KV UG Cable installing 100kva DTR, 350 mtr 3ph and 1km 1ph	100	2641200
Thodupuzha	6	Eechampetty kudi	Laying LT 3ph-450mtr,1ph- 1km	50	1069000
	7	Thayannaankudi	Laying 7km 11 KV UG Cable installing 100kva DTR, 300 mtr 3ph and 700mtr 1ph	40	31016000
	8	Oonchamparakudy	Laying 700mtr LT3ph 200mtr-1ph	10	462313
	9	Alampettykudi	Laying 5.5km 11 KV UG Cable installing 100kva DTR, 250 mtr 3ph and 800mtr 1ph	70	19934000

Electrical Circle	Sl no.	Name of Colony	Quantum of work for grid extension	No. of Houses	Estimate Amount
	10	Puthukudi	Laying 4 km 11 kV UG cable installing 100 kVA DTR, 500 m 3 ph & 2000 m 1 ph	60	11617200
	11	Vellakkallukudi	Laying 2 km 11 kv UG cable installing 100 KVA DTR, 500 m 3 ph & 2000 m 1ph	60	7690200
	12	Chempakkadkudi	Laying 8km 11 KV UG Cable installing 100kva DTR, 600 mtr 3ph and 1kmr 1ph	85	34776500
Thodupuzha	13	Palapettykudi	11 kV UG cable - 0.755 km, LT ABC -0.31 Km	43	16506000
	14	Mulakamuttikudy	4 km 11 kV UG cable, 1.7 m LT ABC and 100 KVA transformer	21	18500000
	15	Magaparakudi	6km 11 kV UG cable, 1.5 m LT ABC and 100 KVA transformer	18	28000000
Palakkad	16	Pallippara	Construction of 420M LT covered conductor	5	210411
Shornur	17	Anavai	11KV UG cable -10km LT ABC -3 phase- 2.5km	109	26779320
	18	Thadikundu	100KVA Transformer - 2Nos.	42	
	19	Katukumanna	11KV UG cable - 4km LT ABC -3 phase- 1.5km 100KVA Transformer - 1No.	48	12323002
	20	Murugala	11KV UG cable - 2km	9	10345062
	21	Palappada	LT ABC -3 phase- 3.5km	4	
	22	Kinattukara	100KVA Transformer - 1No.	21	
Nilambur	23	Thalappali (Vaniyampuzha)	Around 200 mtr HT ABC,1 No 100 KVA Tra,2 km LT ABC	40	3482109
	24	Kumbalappara	3.5 km HT ABC, 3.2 km LT ABC shifting of 25 KVA transformer	21	9651001
	25	Pattakkarimbu(Phase2)	520 m LT UG cable	15	1000000
Total Amount				Rs.24.26 crore	